

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Monday, August 19, 2019

Partial Correction:

1	Misc	WALLS TO BE 2-LAYERED AT STAIRWELLS 1ST FLOORS - REQUIRED FIREBLOCKING AND BOCA PLATES TO BE INSPECTED LATER FROM OPPOSITE SIDE
---	------	---

Comments: