

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183200  
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Tuesday, August 20, 2019

Partial Correction:

1	Misc	INSPECTED ABOVE CEILING ONLY - APPROVED TO ROCK LIDS: EAST WING, ROOMS 135-148; 116-119; 121-124; 126; 128; 130-132; CENTER, SPACES 104-108; 125; 127;
---	------	--

Partial Correction:

2	Misc	OK TO COVER WHEN READY WOOD WALL AND CEILING FRAMING + ENCLOSED SYSTEMS ROUGH-IN AT LOCATIONS: EAST WING UNITS INCLUDING BATHROOMS; A104; 105; CORR 109 <b>INCLUDING E 20'</b> ; 115-118; CORR 121; CORR 123; 124; 131; <b>[106-108; 110; 112; 113; 130; 132;</b>
---	------	---

**Comments:**