

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191736
Address: 521 NW SHAMROCK AVE, Unit:2022, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE,
Unit:3022, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, Unit:1022, LEES
SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Tuesday, August 20, 2019

Partial Correction:
1 Misc UNIT 2022:
AFTER NAIL PATTERN IS CHECKED AND COMPLETED AT 6" & 12" OK TO COVER BOTH NEW SHEAR WALLS

Comments: