

Inspection Summary

Permit #: PRSITE20191463, Development - Site
Goddard School - Chapel Ridge
Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer Construction Inspection	John Jackson	Partial	Tuesday, August 20, 2019

Informational

1 Contractor tie-in 8x6 wye sanitary line with two 8" hard back Fernco coupling. Approximately 42' of 6" sanitary line.

Comments: