CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170409

Address: 3570 SW HOLLYWOOD DR, Unit:7, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection Mark Harding Failed Tuesday, August 20,

2019

Corrective Action Required:

THE FOLLOWING First layer of Sheetrock on ceiling on 3rd floor, and stair towers in building 7

AREAS ARE approved to continue work.

APPROVED

Corrective Action Required:

2 Misc 2nd layer of ceiling on the 3rd floor layers not off set from 1st 24" as per UL

listing.

Comments: