

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190589
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Wednesday, August 21, 2019

Corrective Action Required:

1	Misc	2ND FLOOR: 3RD PARTY INSPECTION REPORT REQUIRED CERTIFYING ALL HOLD-DOWNS HAVE BEEN CHECKED AND APPROVED
---	------	--

MC ELECTRICAL CABLE MUST BE SECURED WITHIN 12" OF ENTRY TO BOX

Comments: