

PLANS REVIEW CONDITIONS

Permit No: PRCOM20191460	Date: August 21, 2019
Project Title: VISONI SALON & STUDIOS	Applicant:
Location: 1160 NE DOUGLAS ST, LEES SUMMIT, MO 64086	ELECTRONIC SYSTEMS INTEGRATION LLC 6516 N LONDON DR KANSAS CITY, MO 64151
Type of Work:	
Occupancy Group: B	
Description: TENANT FINISH FOR HAIR SALON	
Construction Type: Type VB (Unprotected)	Primary: (913) 626-0263
Map Page: 195B	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing for the fire alarm. Testing must be complete before a final occupancy inspection can take place.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.