

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Certificate of Occupancy

Permit #: PRCOM20191742
Address: 314 SW BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Thursday, August 22, 2019
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| | | | |
|-------------------------------|------------|-------------|------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Occupancy Inspection - | John Borns | Full C of O | Thursday, August |
| Codes Commercial | | | 22, 2019 |

Comments: AT F.D. AT FURNACE REPAIR GRATE TO PREVENT ENTRY OF DEBRIS. DIMENSIONS OF RESTROOMS NOT SUFFICIENT FOR ACCESSIBILITY COMPLIANCE, BUT NEW WORK HAS BEEN COMPLETED WITHIN SUBSTANTIAL COMPLIANCE.