

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190346  
Address: 4508 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Steve Quaid	Failed	Thursday, August 22, 2019

Corrective Action Required:

1	Misc	**Final stabilization is needed for the yard **Range vent hood is not installed **Take off boots on round duct in basement are not sealed ** Duct work is not completed **Splash blocks need to be installed
---	------	--

**Comments:**