

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183816
Address: 4513 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Thursday, August 22, 2019

Corrective Action Required:

1	Misc	**Support water heater vent ** Need handrail to basement ** Main level 1/2 bath light is not installed **Upstairs bedroom 1 egress window needs hand crank **Need self closer on garage door **Post address **Final ground stabilization **Porch is missing a joist hanger on the outside corner
---	------	---

Comments: