

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20183809**
Address: **4521 SW NAUTILUS PL, LEES SUMMIT, MO 64082**
Inspected On: **Thursday, August 22, 2019**
Inspected By: **Brandon Kalwei**
Expiration Date: **9/23/2019 12:00:00 AM**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Temporary C of O	Thursday, August 22, 2019

Corrective Action Required:

1	Misc	sod, final grade, splash blocks - anti syphon devise needed for spicket in basement, water line needs to be secured mid way -irrigation permit needed and back flow test needs to be submitted to water department
---	------	--