

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191098  
Address: 4060 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Failed	Thursday, August 22, 2019

Corrective Action Required:

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. INSTALL SILT FENCE ALONG THE STREET AND CLEAN SOME DIRT/MUD OFF THE STREET
---	----------------------	--

NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

**Comments:**