

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191408

Address: 2101 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Khanh Nguyen	Partial	Friday, August 23, 2019

Corrective Action Required:

1	Misc	UNDERSLAB UNDER SERVICE BAYS 153&154&155: SUBMIT AS-BUILT FOR CHANGE IN LOCATION OF THE TRENCH DRAIN AND DELETE OF EXISTING 4" DRAIN CONNECTION TO THE WASTE PUMP
---	------	---

**Comments:**