

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191460
Address: 1160 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Monday, August 26, 2019

Corrective Action Required:

1	Misc	LSCO 7-608: GAS PIPING PRESSURE TEST BELOW LEE'S SUMMIT 10 PSI REQUIRED MINIMUM
---	------	--

Partial Correction:

2	Misc	NO ISSUES FOUND WITH NEW ROOFTOP PIPING EXCEPT CONNECTION TO UNIT YET TO BE COMPLETED
---	------	--

Comments: