

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRPWFC20173801  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	John DiMauro	Failed	Monday, August 26, 2019

Corrective Action Required:

1	Misc	FAILED EROSION CONTROL INSPECTION.
---	------	------------------------------------

Erosion control devices need to be installed and maintained for the project along the east side of SW Cheddington RD. Install ESC devices within 24 hours.

**Comments:**