

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20191541	Date:	August 27, 2019
Project Title:	MARTIN CITY PIZZA & TAPS	Applicant:	
Location:	354 SW BLUE PKWY, LEES SUMMIT, MO 64063		
Type of Work:			ADVANTAGE FIRE PROTECTION SYSTEMS INC
Occupancy Group:	A-2		404 B NW 11TH ST
Description:	TENANT FINISH FOR PIZZA		BLUE SPRINGS, MO 64015
RESTAURANT		Primary:	(816) 224-3400
Construction Type:	Type IIB (Unprotected)		
Map Page:	195K		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.