

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20190280**
Address: **4418 SW AMETHYST DR, LEES SUMMIT, MO 64082**
Inspected On: **Tuesday, August 27, 2019**
Inspected By: **Steve Quaid**
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Temporary C of O	Tuesday, August 27, 2019

Corrective Action Required:

2	Misc	** Final ground stabilization is required **
		** Water discharge is to be 3' from foundation **