

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190683
Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, August 28, 2019

Partial Correction:

1 Misc

OBSERVED THE OVERDUG FOOTING TRENCH. SOIL APPEARS TO BE ORIGINAL SOIL. 3RD PARTY SPECIAL INSPECTION IS ON SITE TO TEST THE SOIL. FLOWABLE FILL WILL BE POURED TO FOOTING LEVEL UPON APPROVAL OF THE SPECIAL INSPECTOR.

Comments: