

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20184043
Address: 1905 NE CATALINA AVE, LEES SUMMIT, MO 64064
Inspected On: Wednesday, August 28, 2019
Inspected By: Khanh Nguyen
Expiration Date: 9/30/2019 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Wednesday, August 28, 2019

Corrective Action Required:

1	Misc	-Sod,, and splash blocks -Bond gas piping -Water meter must be at final grade level. Distance from meter top to lid must be 14"-18" -Make sure the sewer tracer box and wire at grade level
---	------	--