

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170403

Address: 3540 SW HOLLYWOOD DR, Unit:4, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Wednesday, August 28, 2019

Corrective Action Required:

1	Misc	Erosion control needs installed ASAP on cheddington dr west of building 4-5. Room 103 -clean out in bedroom needs cover sheetrocked over . Storage Room Storage room 19 COVERED -clean out needs cover It room fire caulk South Mechanical room -, fire caulk around heat ducts.
---	------	--

Comments: