

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183171
Address: 1630 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Thursday, August 29, 2019

Corrective Action Required:

1	Misc	1.DECK LEDGER BOARD ATTACHMENT NOT ALLOWED TO ATTACH TO CANTILEVER. DOUBLE HEADER AND DOUBLE BOTH SUPPORTING JOISTS . INSTALL JOIST HANGERS AT ALL.
---	------	--

Comments: