

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Joe Starlin	Partial	Friday, August 30, 2019

Informational: 3	Misc	7-24-19 10:22AM Silt fence is down on the west side of site along Ward RD. Silt fence is down along the north side of site alone Tudor RD. As well. There is lots of silt on the sidewalks that needs cleaned up.
Informational: 4	Misc	8-21-19 There is one small section of silt fence down along Ward rd. Everything else seems to be compliant at this time. I will call Jonathan Myers so that he is aware of it.
Informational: 1	Misc	5-23-19 Silt fence is down in random spots of the job site. I called Jonathan Myers the project manager at 8:45am about the erosion control, he said he would address the problem areas.
Informational: 2	Misc	6-11-19 The silt fence is down on the south side of the site. The west side of the site has silt fence down and is missing sections completely. I will be emailing Jonathan Myers about the matter.
Informational: 5	Misc	8-30-19 10:03am Rain. All erosion control appears to be in place and working at this time.

Comments:

