

Inspection Summary

Permit #: PRSITE20191463, Development - Site

Goddard School - Chapel Ridge

Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------------|-----------------|---------------------------------|
| DE - Storm - Sewer Construction Inspection | Steve Robbins | Partial | Thursday, August 29, 2019 |

Informational

- 1 The contractors core drilled into the existing storm box and made the connection of the 3 lines going into the box. They are planning on grouting the pipes in the morning. I let them know they needed to smooth out the inverts as the flow has changed due to the new pipes flowing into the box. Steve Robbins 08/29/2019 4:50 PM

Comments: