

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183155
Address: 3329 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Partial	Wednesday, September 04, 2019

Corrective Action Required:

1	Misc	-stud shoe needed for laundry drain pipe and *****stud to the left of it, **** still needs done -Support vent pipe in basement mid way in bathroom**** -Support waterline south side foundation wall mid way**** -ok to insulate
---	------	--

Comments: