

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182954
Address: 4716 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, September 04, 2019

Corrective Action Required:

1	Misc	-Final grade, sod, splashblocks
		-Expose sewer manhole at front corner of lot.
		-Install handrail per code at front stair
		-Fb basement from garage
		-At any point along the kitchen countertop wall , there must be a receptacle within two ft

Comments: