

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

September 04, 2019

DIAMOND CONTRACTORS INC
4224 NE PORT DR
LEES SUMMIT, MO 64064

Permit No: PRCOM20192490
Project Title: TERRA HEALTH & WELLNESS
Project Address: 1134 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Parcel Number: 52910140800000000
Location / Legal Description: DOUGLAS STATION COMMERCIAL PARK LOTS 3-A, 4-A & 5-A---LOT 3-A
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: TENANT FINISH FOR SMOOTHIE SHOP - ONLY CONSTRUCTION IS ELECTRICAL, NEW COUNTER TOPS AND NEW SINKS

**drawings are in plan review file

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Approved

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

2. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is for informational purposes.

DEVELOPMENT SERVICES

3. 2018 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

ICC A117.1-2017 Section 904.3 Sales and service counters and windows. Sales and service counters and windows shall comply with Section 904.3.1 and either 904.3.2 or 904.3.3. Where counters are provided, the accessible portion of the countertop shall extend the same depth as the public portion of the sales and service countertop provided for standing customers. (see code for exception)

904.3.1 Vertical barriers. At service windows or service counters, any vertical barrier between service personnel and customers shall be at a height of 43 inches maximum above the floor. (see code for exception regarding security glazing)

904.3.2 Parallel Approach. A portion of the public use side of the counter surface 36 inches minimum in length and 26 inches minimum and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a parallel approach adjacent to the accessible counter shall be provided. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12 inches minimum. (see code for exception)

904.3.3 Forward Approach. A portion of the public use side of the counter surface 30 inches minimum in length and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a forward approach to the accessible counter shall be provided. Knee and toe clearance complying with Section 306 shall be provided under the accessible counter. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12" minimum.

Action required: At least 36" of new counter must be accessible per listed requirements. (to be verified in field)

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

2. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide one 2A10BC fire extinguisher

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.