

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190447
Address: 1801 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Steve Quaid	Failed	Wednesday, September 04, 2019

Corrective Action Required:

1	Misc	<p>** Three I-beams in basement have been extended anywhere from 3" to 6". Please supply an engineers approval of this repair method **</p> <p>** 3" hole in floor between master bathroom and bathroom by exterior wall needs to be draft stopped **</p> <p>** Cleanout in basement by bathroom does not have the required clearance **</p> <p>** Wall studs in basement bathroom wall need stud shoes **</p> <p>** A stud shoe is needed in wall between bathroom and master bathroom **</p>
---	------	--

Comments: