

DEVELOPMENT SERVICES

Building Permit - Residential		Permit No: PRRES20192443		
Project Title:		Date Issued: September 04, 2019		
Work Desc: NEW SINGLE FAMILY				
Project Address:		Permit Holder:		
2915 SW ARBOR TREE DR, LEES SUMMIT, MO 64082		SUMMIT HOMES		
		120 SE 30TH ST		
Legal Description: HAWTHORN RIDGE 1ST PLAT, LOTS 1		LEES SUMMIT, MO 64082		
THRU 100, INCLUSIVE AND TRACTS A, B, C, D & ELOT 56				
Parcel No: 69620010300000000				
County: JACKSON				
		•		
Activities Included for this Project:				
zNew Single Family, Right of Way, Licens	e Tax, License Tax Cr	edit, Deck - Covered	Residential,	
Construction Type: Type VB	Occupancy: RESIDENTIAL, ONE- AND Zoning District: PMIX			
(Unprotected)	TWO-FAMILY			
	Valuation: \$324,30	8.25		
			•	
Residential Area:				
Residential, Living Area 2		735		
Residential, Living Area		1401		
Residential, Un-Finished basements		1301		
Residential, garage		688		
Commercial Area		2136 sq. ft.		
Issued By:KB		Date: Sep 04, 2019		
		•		
THIS PERMIT IS ISSUED IN RELIANCE UPC	N INFORMATION SU	IBMITED BY THE APP	LICANT. THE BUILDING OFFICIAL MAY	

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.

NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Plot Plan Review	
Residential Plan Review	

Signature of	
Signature of Applicant:	Date:SEPTEMBER 4, 2019
Print name:	Company Name:SUMMIT HOMES

Designate locations of smoke detectors and carbon monoxide detectors. (IRC Section R314 and R315)

1

No smoke detector shown in basement and bedroom #4