

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20181667
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Proof Roll	John DiMauro	Passed	Thursday, September 05, 2019

Corrective Action Required:

1	Misc	The roll test for the west turn lane on SW Pryor Rd. Failed. There were a few sections of the sub-grade with deflection during the test. The Spalding crew is going to address the soft areas today and set up another proof roll for tomorrow.
---	------	---

Comments: