

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Failed	Friday, September 06, 2019

Corrective Action Required:

1	Misc	PRESSURE GAUGE DOES NOT "ZERO" WHEN PRESSURE IS LET OFF. REPLACE GAUGE AND PRESSURIZE TO ≥ 10 PSI; REQUEST RE-INSPECTION.
---	------	--

Comments: