

Inspection Summary

Permit #: PRSITE20183577, Development - Site
INTERNATIONAL BUILDERS AND CONSULTANTS, INC
Address: 2320 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Driveway Inspection	John Jackson	Partial	Monday, September 09, 2019
Informational			
1	Concrete Parking Lot was poured in the rear of building & Asphalt was layed in the front of business.		
DE - Water Line - Tapping Sleeve	John Jackson	Passed	Monday, September 09, 2019
Informational			
1	Water tap 12" water main so the contractor Icon could run a 2" domestic water line to the water meter. From the meter connect to the building.		

Comments: