

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190589
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Monday, September 09, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY WALL FRAMING & SYSTEMS TO BE CONCEALED IN WALL CAVITIES AT: WEST STAIRWELL; 2ND FLOOR EXTERIOR WALLS ONLY; **3RD FLOOR INTERIOR WALLS;**

SPOT CHECK OF HOLD-DOWNS FOUND SOME NUTS NOT TIGHTENED. G.C. WAS INFORMED.

Comments: