

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190763
Address: 4836 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Monday, September 09, 2019

Corrective Action Required:		
1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. SHALL RESTORE EROSION CONTROL ALONG THE STREET. AT THE LOT ENTRANCE, PROVIDE MIN. 3/4" GRAVEL FILTER

NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Comments: