

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190280
Address: 4418 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Monday, September 09, 2019

Corrective Action Required:

1	Miscellaneous Correction	** Final ground stabilization is required ** ** Water discharge is to be 3' from foundation **
---	--------------------------	---

Obtain Driveway approval.
Submit As-Graded Plot plan
MARK HARDING 09/09/2019 7:20 AM

Comments: