

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192479
Address: 18 SW 3RD ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Monday, September 09, 2019

Corrective Action Required:

1	Misc	ADDRESS LABELING OF GAS SERVICE ENTRY PIPE: HANG PERMANENT TAG FROM LOAD SIDE ENTRY PIPE.
---	------	--

Corrective Action Required:

2	Misc	ADDRESS LABELING OF ELECTRICAL SERVICE METER/DISCONNECT: APPLY PERMANENT ADDRESS STICKERS
---	------	--

Corrective Action Required:

3	Misc	RECOMMENDED MAINTENANCE: - ENSURE ALL ELECTRICAL RECEPTACLES ARE SCREWED SOLID TO BOXES. USE YOKE SPACERS OR SPARK RINGS AS REQUIRED. - ONE SURFACE-MOUNTED ELECTRICAL RECEPTACLE BOX NOT SECURED TO WALL. MAKE SOLID. - ONE UNUSED OPENING AT SURFACE-MOUNTED ELECTRICAL RECEPTACLE BOX NEEDS TO BE PLUGGED. - WHEN PAINTING IS COMPLETED APPLY FACE PLATES TO ALL ELECTRICAL RECEPTACLES AND SWITCHES.
---	------	--

Comments: