

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191391
Address: 1837 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|----------|----------------------------|
| All Rough Inspection - Residential | Steve Quaid | Failed | Monday, September 09, 2019 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | ** Loose bottom plate bolts in garage ** **HVAC Duct work is not sealed with UL 181 tape** **Missing straps at garage door header ** ** Stud shoes needed in master bath plumbing wall** ** Draft block center of fire place framing ** |
|---|--------------------------|--|

Comments: