



### **PLAN REVIEW CONDITIONS**

September 09, 2019

BRASSTACKS INC  
2731 S 65TH ST  
KANSAS CITY, KS 66106

Permit No: PRCOM20191957  
Project Title: HEALTHY LOOKS MEDSPA  
Project Address: 930 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086  
Parcel Number: 51700033700000000  
Location: SUMMIT FAIR, LOTS 31 & 32-PT LOT 32 DAF: BEG NW COR SE 1/4 SEC-36 TWP-48 RNG-32 TH S 2 DEG 28 MIN 52 SEC E & RAD 139') 74.01' TH S 00 DEG 57 MIN 28 SEC W 65.80' TH S 89 DEG 10 MIN 24 SEC E 231.21' TH S TH SELY ALG LF CURV (RAD 111') 67.86' TO POINT OF REVERSE CURV SELY & SLY ALG RI CURV (RAD 139') 85. W 44.01' TH S 79 DEG 07 MIN 37 SEC E 49.50' TH S 10 DEG 52 MIN 23 SEC W 54.98' TH S 2 DEG 59 MIN 20  
Type of Work: CHANGE OF TENANT  
Occupancy Group: BUSINESS  
Description: TENANT FINISH FOR MEDSPA

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Fire Plan Review**

**Reviewed By: Michael Weissenbach**

**Approved with Conditions**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. (Action Required)

Any modifications made to the alarm system, provide three sets of PE stamped shop drawings.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters.

Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications made to the sprinkler system, provide three sets of PE stamped shop drawings.

4. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

5. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(verified At Inspection)

Provide one 2A10BC extinguisher

6. 2018 IFC 1008.1 Illumination required. The means of egress, shall be illuminated at all times the building space served by the means of egress is occupied.

(Verified At Inspection)

Provide exterior emergency lighting at the exit doors.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Pending**

1. All plans submitted for review on or after April 1, 2019 shall be designed to the requirements of the 2018 International Building Code, 2018 International Mechanical Code, 2018 International Plumbing Code, 2018 International Fuel Gas Code, 2018 International Fire Code, 2017 National Electric Code and the ICC/ANSI A117.1-2017 as amended and adopted by the City of Lee's Summit

Action required: Update code references.

2. 2018 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed. ICC A117.1-2017 Section 904.3 Sales and service counters and windows. Sales and service counters and windows shall comply with Section 904.3.1 and either 904.3.2 or 904.3.3. Where counters are provided, the accessible portion of the countertop shall extend the same depth as the public portion of the sales and service countertop provided for standing customers. (see code for exception)

904.3.1 Vertical barriers. At service windows or service counters, any vertical barrier between service personnel and customers shall be at a height of 43 inches maximum above the floor. (see code for exception regarding security glazing)

904.3.2 Parallel Approach. A portion of the public use side of the counter surface 36 inches minimum in length and 26 inches minimum and 36 inches maximum in height above the floor shall be provided. A

clear floor space positioned for a parallel approach adjacent to the accessible counter shall be provided. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12 inches minimum. (see code for exception)

904.3.3 Forward Approach. A portion of the public use side of the counter surface 30 inches minimum in length and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a forward approach to the accessible counter shall be provided. Knee and toe clearance complying with Section 306 shall be provided under the accessible counter. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12" minimum.

Action required: Reception desk to have at least 3' of accessible area. To be field verified

3. 2018 IBC 1008.3 – Emergency power for illumination. The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.

1008.3.1 General. In the event of power supply failure in rooms and spaces that require two or more means of egress, an emergency electrical system shall automatically illuminate all of the following areas:

1. Aisles.
2. Corridors.
3. Exit access stairways and ramps.

1008.3.2 Buildings. In the event of power supply failure in buildings that require two or more means of egress, an emergency electrical system shall automatically illuminate all of the following areas:

1. Interior exit access stairways and ramps.
2. Interior and exterior exit stairways and ramps.
3. Exit passageways.
4. Vestibules and areas on the level of discharge used for exit discharge in accordance with Section 1028.1.
5. Exterior landings as required by Section 1010.1.6 for exit doorways that lead directly to the exit discharge.

1008.3.3 Rooms and Spaces. In the event of power supply failure an emergency electrical system shall automatically illuminate all of the following areas:

1. Electrical equipment rooms.
2. Fire command centers.
3. Fire pump rooms.
4. Generator rooms.
5. Public restrooms with an area greater than 300 square feet.

Action required: Provide emergency lighting at exterior side of exit doors.

4. 2017 NEC 210.8 (B) Other Than Dwelling Units. All 125-volt, single-phase, 15- and 20-ampere receptacles installed in the locations specified in 210.8(B)(1) through (10) shall have ground-fault circuit-interrupter protection for personnel.

- (1) Bathrooms
  - (2) Kitchens
  - (3) Rooftops
  - (4) Outdoors
  - (5) Sinks - where receptacles are installed within 6 feet of the outside edge of the sink.
  - (6) Indoor wet locations
  - (7) Locker rooms with associated showering facilities
  - (8) Garages, service bays, and similar areas other than vehicle exhibition halls and showrooms.
  - (9) Crawl spaces – at or below grade level.
  - (10) Unfinished portions or areas of the basement not intended as habitable rooms.
- (refer to code for exceptions)

Action required: Modify drawings to show that all receptacles within 6' of a sink will be GFCI protected.  
(ref: Exam Rooms 1 & 3)

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***