

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20184050
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Hydrostatic Test	John DiMauro	Passed	Monday, September 09, 2019

Informational:

1 Misc

The Redford Construction crew performed the hydro test for the public water main. I observed the gauge hold at 150 psi for two hours. The test passed. The crew plans to chlorinate the line either tomorrow or Wednesday 9/11/19.

Comments: