

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Tuesday, September 10, 2019

Partial Correction:

1	Misc	GAS PIPING FROM INTERSECTION OF CORR A121 & CORR A123 SOUTH TO ROOF ABOVE RM A111 HELD PRESSURE AT >10 PSI FOR >10 MIN - APPROVED.
---	------	--

Comments: