

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20191541	Date:	September 10, 2019
Project Title:	MARTIN CITY PIZZA & TAPS	Applicant:	
Location:			
354 SW BLUE PKWY, LEES SUMMIT, MO 64063		FIRE ONE INC	
Type of Work:		3718 ROBINSON PIKE RD	
Occupancy Group:	A-2	GRANDVIEW, MO 64030	
Description:	TENANT FINISH FOR PIZZA	Primary:	(816) 761-0777
RESTAURANT			
Construction Type:	Type IIB (Unprotected)		
Map Page:	195K		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Action Required)

Call (816)969-1300 to schedule alarm testing.

2. Provide outside horn/strobe. Locate by FDC.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**