

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	Joe Starlin	Passed	Tuesday, September 10, 2019

Informational:
1 Misc 8-28-19 We pulled the first water sample at 12:40pm Last sample was pulled 1:07pm. Samples were delivered to the lab at 1:40pm.

Informational:
2 Misc 9-5-19 John Jackson pulled 1-E sample and took it to the lab.

Informational:
3 Misc 9-10-19 The sample passed.

Comments: