

joe

From: Spencer, Aaron <Aaron.Spencer@trane.com>
Sent: Wednesday, September 4, 2019 9:51 AM
To: Joe Dintino
Cc: Linda
Subject: Fwd: Pro Builders Weights Needed

Flag Status: Flagged

Please see the curb weights below from CDI curbs.

Aaron Spencer

Account Manager

Climate Solutions

Trane Light Commercial

Mobile: 913-205-5298

E-mail: Aaron.Spencer@Trane.com

From: Jeremy Timm <jtimm@cdicurbs.com>
Sent: Wednesday, September 4, 2019 9:26:44 AM
To: Spencer, Aaron <Aaron.Spencer@trane.com>
Cc: Robert Anderson <randerson@cdicurbs.com>
Subject: Re: Pro Builders Weights Needed

Alert: This is an external email.

Aaron,

This would be about 250 lbs

Quote, track orders, online ordering and more at:


<https://www.cdicurbs.com>

Thank you,

Jeremy (JT) Timm:
Inside Sales

contact: jtimm@cdicurbs.com
office: 888-234-7001
direct: 763-201-6656

EXISTING CURB LAYOUT



Aaron Spencer

Account Manager Mid-America

Trane Commercial Systems - Ingersoll Rand

11211 Lakeview Ave

Lenexa KS, 66219

Office: 913-307-8659

Mobile: 913-205-5298

"Do you need to replace your Light Commercial Unitary Equipment of 25-Tons or less?"






We'll make it happen! Call for a quote or to place an order now!"

To New 10 Ton Trans

OPTIONS:
MATERIAL: 18ga. GALV STEEL
INSULATED PANELS (WHERE REQUIRED)
1" 1-1/2" B DUCT INSULATION (R VALUE 3.56)
GASKET PROVIDED WITH CURB
1 1/2" ADDED TO EXISTING CURB O.D.

Attn: _____
Tag: _____
Approval: _____

REV.	ECO #	DESCRIPTION	DATE	APPROVED
1		INITIAL DRAWING	7/3/19	BDR



CURB SHOWN IS CDI STANDARD CONFIGURATION CDI RESERVES THE RIGHT TO CHANGE LAYOUT WITHOUT NOTIFICATION. IF CURB IS NEEDED IN A DIFFERENT CONFIGURATION CDI MUST BE NOTIFIED PRIOR TO PLACING AN ORDER.
OPERATIONAL HEIGHT OF CDI ADAPTER IS 3" LESS THAN OVERALL CURB HEIGHT SHOWN.






THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE PROPERTY OF CDI. NO PART OF THIS DRAWING IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING FROM CDI. ALL RIGHTS RESERVED.		APPROVALS		DATE		TITLE/ID NAME	
DESIGNED BY: bdr		7/3/2019		1355057-1-9999-3105			
CHECKED BY: [Signature]		7/3/2019		227.07			
CDI		Contact us @		www.cdi.com		APPROXIMATE CURB WEIGHT (LBS.)	
1-888-244-7001		227.07		227.07		1	
		SCALE: 1/2"		SHEET: 1		OF: 3	

To New 7 1/2 ton TRANE

OPTIONS:
 MATERIAL: 18 ga. GAL STEEL
 INSULATED PANELS (WHERE REQUIRED)
 1" 1-1/2" B DUCT INSULATION (R VALUE 3.85)
 GASKET PROVIDED WITH CURB
 1 1/2" ADDED TO EXISTING CURB O.D.

Attn: _____ Tag: _____
 Approval: _____

REV.	DESCRIPTION	DATE	APPROVED
1	INITIAL DRAWING	3/4/2013	EH
5	UPDATED BRACES		



CURB SHOWN IS CDI STANDARD CONFIGURATION CDI RESERVES THE RIGHT TO CHANGE LAYOUT WITHOUT NOTIFICATION. IF CURB IS NEEDED IN A DIFFERENT CONFIGURATION CDI MUST BE NOTIFIED PRIOR TO PLACING AN ORDER.

VERIFY EXISTING CURB O.D.
 VERIFY SUPPLY AND RETURN OPENINGS
 CALL WITH ANY QUESTIONS
 FOR BRACE DESIGNING IS OK AS IS

CURB WEIGHT (LBS.) 177.16		APPROVALS		DATE		TITLE	
177.16		Signature		Monday, March 04, 2013 8:14:23 AM		1-5010-3105	
CDI		17850 TYLER ST NW ELK RIVER, MN 55330 (763) 351-7161		QUOTE #		1-5010-3105	
SCALE: 1/25		SHEET: 1		OF: 4		5	

Base unit dimensions — 48TF008-014

