

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

September 11, 2019

BRINKMANN CONSTRUCTORS
8700 INDIAN CREEK PKWY, SUITE 150
OVERLAND PARK, KS 66210

Permit No: PRCOM20192096
Project Title: SUMMIT AT WEST PRYOR
Project Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081
Parcel Number: 197510
Location / Legal
Description:
Type of Work: NEW COMMERCIAL
Occupancy Group: MIXED OCCUPANCY
Description: NEW 4 STORY APARTMENT BUILDING WITH RETAIL SHELLS ON MAIN LEVEL AND PARKING
BENEATH
Constr Types:
Bldg A - 1A
Bldg B - 5A
Bldg C - 2B
Bldg D - 5A
Bldg E - 5A

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. (Verified At Inspection)
2. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

DEVELOPMENT SERVICES

(Action Required)

Provide three sets of PE stamped shop drawings for the alarm system.

3. 2018 IFC 403.11.1.5 - Tenant identification. Each occupied tenant space provided with a secondary exit to the exterior or exit corridor shall be provided with tenant identification by business name and/or address. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and shall contrast with their background.

(Verified At Inspection)

4. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

5. 2018 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

(Verified At Inspection)

Order one Knox Box for the exterior of the building and two Elevator Knox Boxes. Place order through knoxbox.com.

6. 2018 IFC 510.1- Identification. Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location, shall be constructed of durable materials, permanently installed and readily visible.

(Verified At Inspection)

7. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Provide three sets of PE stamped shop drawings for the fire sprinkler system. Class 1 standpipes to be installed.

8. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing. All life safety must pass before a final occupancy can take place.

9. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

DEVELOPMENT SERVICES

11. 2018 IFC (B) 1023.9 Stairway identification signs. A sign shall be provided at each floor landing in an interior exit stairway and ramp connecting more than three stories designating the floor level, the terminus of the top and bottom of the interior exit stairway and ramp and the identification of the stair or ramp. The signage shall also state the story of, and the direction to, the exit discharge and the availability of roof access from the interior exit stairway and ramp for the fire department. The sign shall be located 5 feet (1524mm) above the floor landing in a position that is readily visible when the doors are in the open and closed positions. In addition to the stairway identification sign, a floor-level sign in raised characters and Braille complying with the ICC A1 17.1 shall be located at each floor-level landing adjacent to the door leading from the interior exit stairway and ramp into the corridor to identify the floor level.

(Verified At Inspection)

12. 2018 IFC (B) 1023.8 Discharge identification. An interior exit stairway and ramp shall not continue below its level of exit discharge to prevent persons from unintentionally continuing into levels below. Directional exit signs shall be provided as specified in Section 1011.

(Informational Purposes)

14. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

(Verified At Inspection)

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. The building permit for this project can not be issued until the Codes Administration Department has received the approved Final Development Plan from the Planning and Development Department.

Action required: Comment is for informational purposes.

3. Prior to the installation or construction of any elevator equipment, an elevator equipment permit shall be obtained from the Missouri Department of Public Safety or its authorized representative.

Action required: Comment is for informational purposes.

4. Prior to the operation of any new elevator equipment or the issuance of the operating certificate, such elevator equipment shall be inspected by a licensed inspector. Testing must be performed in accordance with these rules and regulations. The testing must be witnessed by a licensed inspector.

Action required: Comment is for informational purposes.

5. Elevator Safety Act and Rules 701.361 - Each privately owned or operated installation and each installation owned or operated by the state of Missouri or any political subdivision of the state shall have a certificate of inspection and meet the safety code promulgated pursuant to sections 701.350 to 701.380.

Action required: Comment is for informational purposes.

6. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

DEVELOPMENT SERVICES

Action required: Comment is for informational purposes.

7. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

8. Copies of the engineered truss package were not provided at the time of permit application.

Action required: Provide truss packages or request deferral.
9/11/19 - deferred per request

9. Copies of the pool design package was not provided at the time of permit application.

Action required: Provide pool design package or request deferral.
9/11/19 - deferred per request

16. 2018 IPC 708.1.3 Building drain and building sewer junction. The junction of the building drain and the building sewer shall be served by a cleanout that is located at the junction or within 10 feet of the developed length of piping upstream of the junction. For the requirements of this section, the removal of a water closet shall not be required to provide cleanout access.

Action required: Provide cleanouts where sanitary drain piping leaves building footprint.
9/11/19 - Response letter refers to sheet P1.10 which has not been provided. (original submittal did not have any P1.xx sheets) Underslab plan P103 does not show all of the required cleanouts.

18. Insufficient information to complete review.

Provide the following:

- Plumbing DWV riser diagrams.

9/11/19 - Response letter refers to sheets P1.14 and P1.16 which have not been provided. (original submittal did not have any P1.xx sheets)

- Feeder info approved

19. 2018 706.6 Vertical continuity. Fire walls shall extend from the foundation to a termination point not less than 30 inches above both adjacent roofs.

Exceptions: (see code for complete list)

4. In buildings of Types III, IV and V construction, walls shall be permitted to terminate at the underside of combustible roof sheathing or decks provide that all of the following are met: (see code for complete list)

4.1. Roof openings are not less than 4 feet from the fire wall.

Action required: There shall be no roof penetrations within 4' of fire walls. (to be field verified)
9/11/19 - acknowledged in letter

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

DEVELOPMENT SERVICES

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.