

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191536
Address: 1109 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Thursday, September 12, 2019

Corrective Action Required:

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. -EROSION CONTROL IS NOT INSTALLED AROUND THE LOT -SILT FENCE ALONG THE STREET IS TORN DOWN AND MUST BE REPLACED -MUD AND DIRT SHALL BE CLEANED OFF THE STREET -CLEAN OUT MUD DEPOSIT AT GUTTY BUDDY **EROSION CONTROL SHALL BE IN COMPLIANCE IN TWO BUSINESS DAYS **INSPECTION DENIED
---	----------------------	---

Comments: