

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191898
Address: 115 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Failed	Thursday, September 12, 2019

Corrective Action Required:

1	Misc	ACCESSIBLE RESTROOM SIGN MUST INCLUDE WHEELCHAIR SYMBOL
---	------	---

Corrective Action Required:

2	Misc	BLUNDER PLUG REQUIRED AT ONE SURFACE-MOUNTED ELECT BOX WITH UNUSED OPENING.
---	------	---

Corrective Action Required:

3	Misc	IN ORDER FOR SPACE TO BE APPROVED FOR OCCUPANCY PERMANENT LIGHTING IS REQUIRED PER CODE.
---	------	--

Comments: