

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172513  
Address: 229 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Steve Quaid	Failed	Friday, September 13, 2019

Corrective Action Required:

1	Misc	incomplete- fire coillars not installed correctly. holes in pre-rock, nail pattern incomplete . fix all issues and reschedule
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	** Ridged channel was over spaced ** 12" o.c. Max
---	-----------------------------	---

**Comments:**