

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191352
Address: 1305 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, September 16, 2019

Corrective Action Required:

1 Misc

FRAMING:

- Nail corner studs per code (16d @12" oc or equivalent nailing)
- Support hip rafters above front bedroom and master closet

PLUMBING:

- Strap top plates where bored more than 50% at rear bathroom wall

****THE UFER GROUNDING CONNECTION AT THE STAIR WALL MUST BE ACCESSIBLE AT FINAL INSPECTION**

Comments: