

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191352
Address: 1305 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Monday, September 16, 2019

Corrective Action Required:

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION. -BOTTOM OF THE SILT FENCE SHALL BE BURIED MIN 6" DOWN. LOOK AT THE FRONT CORNER. MUD JUST FLOWING UNDERNEATH THE SILT FENCE -RESTORE STAKING THE SILT FENCE
---	----------------------	---

LAST WARNING: NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. STOP WORK ORDER WILL BE ISSUED IF EROSION CONTROL IS NOT IN COMPLIANCE

Comments: