

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172513
Address: 229 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Steve Quaid	Not Ready	Monday, September 16, 2019

Corrective Action Required:

1	Misc	incomplete- fire coillars not installed correctly. holes in pre-rock, nail pattern incomplete . fix all issues and reschedule
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	** Ridged channel was over spaced ** 12" o.c. Max
---	-----------------------------	---

Comments: