

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182997

Address: 837 NW DONOVAN RD, Unit:TRASH, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Passed	Tuesday, September 17, 2019

Comments: OK TO POUR WHEN READY CONCRETE WALLS AT TRASH COMPACTOR STRUCTURE.